

Test Verification of Conformity

Verification Number: 220908196GZU-VOC001

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>. This verification replaces previous verification dated: 18 May 2016

Once compliance with all product relevant mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address: UNI-TREND TECHNOLOGY (CHINA) CO.,LTD.

No 6, Gong Ye Bei 1 st Road, Songshan Lake National High-Tech, Industrial Development

Zone, Dongguan, Guangdong Province, China

Product Description: Voltage Testers

Models/Type References: UT15B, UT15C, DL-6780, DL-6790, NLVCT2, NLVCT3

Ratings & Principle 2 x 1,5 V LR03 AAA Battery 12-690 V, CAT IV 600 V UNI-T, Di-LOG, Newlec Relevant Standards/Directives: EN IEC 61326-1:2021

EN IEC 61326-2-2:2021 EMC Directive 2014/30/EU

Verification Issuing Office Intertek Testing Services Shenzhen Ltd. Guangzhou Branch

Name & Address: Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2.

Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China

Date of Tests: 08 September 2022 to 10 November 2022

Test Report Number(s): 150818023GZU-002 Amendment 2

Signature

Name: Sky Zhu

Position: Team Leader Date: 14 November 2022

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.