

Uni-Trend Technology (China) Co., Ltd

TEST REPORT

SCOPE OF WORK

EMC TESTING–UT197

REPORT NUMBER

241012007GZU-001

ISSUE DATE

20 January 2025

[REVISED DATE]

[-----]

PAGES

27

DOCUMENT CONTROL NUMBER

TRF-EN IEC 61326-1:2021-a

© 2023 INTERTEK



TEST REPORT

Applicant Name & Address : Uni-Trend Technology (China) Co., Ltd
No 6, Gong Ye Bei 1st Road, Songshan Lake National High-Tech
Industrial Development Zone, Dongguan City, Guangdong Province,
China
Manufacturing Site : Same as applicant
Intertek Report No: 241012007GZU-001


Test standards

EN IEC 61326-1:2021
EN IEC 61326-2-2:2021

Sample Description

Product : Industrial Digital Multimeter
Model No. : UT197
Electrical Rating : Powered: 3 x 1.5Vdc AA battery
Serial No. : Not Labeled
Date Received : 12 October 2024
Date Test : 12 October 2024 to 14 January 2025
Conducted

Prepared and Checked By



Jed Guo

Project Engineer

Approved By:



Sky Zhu

Team Leader

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Room101/301/401/102/202/302/402/502/602/702/802, No. 7-2, Caipin Road, Huangpu District, Guangzhou, Guangdong,
China

TEST REPORT

CONTENT

TEST REPORT	1
CONTENT	3
1. TEST RESULTS SUMMARY	4
2. EMC RESULTS CONCLUSION.....	5
3. LABORATORY MEASUREMENTS.....	6
4. EQUIPMENT USED DURING TEST	8
5. EMI TEST.....	10
5.1 CONTINUOUS CONDUCTED DISTURBANCE VOLTAGE TEST	10
5.2 RADIATED EMISSION BELOW 1 GHz.....	10
5.2.1 Block Diagram of Test Setup.....	10
5.2.2 Test Setup and Procedure	10
5.2.3 Test Data and Curve	11
6. EMS TEST.....	13
6.1 EN 61000-4-2(PURSUANT TO EN IEC 61326-1) ELECTROSTATIC DISCHARGE IMMUNITY.....	14
6.2 EN 61000-4-3(PURSUANT TO EN IEC 61326-1) RADIATED ELECTROMAGNETIC FIELD IMMUNITY	17
6.3 EN 61000-4-4(PURSUANT TO EN IEC 61326-1) ELECTRICAL FAST TRANSIENT/BURST	20
6.4 EN 61000-4-5(PURSUANT TO EN IEC 61326-1) SURGE IMMUNITY	20
6.5 EN 61000-4-6(PURSUANT TO EN IEC 61326-1) INJECTED CURRENT (0.15 MHz TO 80 MHz)	20
6.6 EN IEC 61000-4-11(PURSUANT TO EN IEC 61326-1) VOLTAGE DIPS AND INTERRUPTIONS...	20
6.7 EN 61000-4-8(PURSUANT TO EN IEC 61326-1) POWER FREQUENCY MAGNETIC FIELD	
IMMUNITY.....	21
7. APPENDIX I - PHOTOS OF TEST SETUP	22
8. APPENDIX II – PHOTOS OF EUT	24

TEST REPORT

1. TEST RESULTS SUMMARY

Test Item	Standard	Result
Conducted disturbance voltage at mains ports	EN IEC 61326-1, EN IEC 61326-2-2 Reference: EN 55011:2016+A1:2017+A11:2020+A2:2021	N/A
Radiated emission	EN IEC 61326-1, EN IEC 61326-2-2 Reference: EN 55011:2016+A1:2017+A11:2020+A2:2021	Pass
ESD immunity	EN IEC 61326-1, EN IEC 61326-2-2 Reference: EN 61000-4-2:2009	Pass
Radiated EM field immunity	EN IEC 61326-1, EN IEC 61326-2-2 Reference: EN 61000-4-3:2006 +A1:2008+A2:2010	Pass
EFT immunity	EN IEC 61326-1, EN IEC 61326-2-2 Reference: EN 61000-4-4:2012	N/A
Surge immunity	EN IEC 61326-1, EN IEC 61326-2-2 Reference: EN 61000-4-5:2014+A1:2017	N/A
Inject current immunity	EN IEC 61326-1, EN IEC 61326-2-2 Reference: EN 61000-4-6:2014	N/A
Power frequency magnetic field immunity	EN IEC 61326-1, EN IEC 61326-2-2 Reference: EN 61000-4-8:2010	N/A
Voltage dips and interruption immunity	EN IEC 61326-1, EN IEC 61326-2-2 Reference: EN IEC 61000-4-11: 2020	N/A

Remark:

1. The symbol "N/A" in above table means Not Applicable.
2. When determining the test results, measurement uncertainty of tests has been considered.
3. The EUT belonging to Class B, Group 1 equipment, as requirement by EN 55011.

TEST REPORT

2. EMC RESULTS CONCLUSION

RE: EMC Testing Pursuant to Radio Equipment Directive 2014/53/EU Performed on the Industrial Digital Multimeter, Model: UT197.

We tested the Industrial Digital Multimeter, Model: UT197 to determine if it was in compliance with the relevant EN IEC standards as marked on the Test Results Summary. We found that the unit met the requirement of EN IEC 61326-1: 2021 and EN IEC 61326-2-2: 2021 standards when tested as received. The worst case's test data was presented in this test report.

The production units are required to conform to the initial sample as received when the units are placed on the market.

TEST REPORT

3. LABORATORY MEASUREMENTS

Configuration Information

Support Equipment:	N/A
Rated Voltage and frequency under test:	3 x 1.5V
Condition of Environment:	Temperature: 22~28°C Relative Humidity:35~60% Atmosphere Pressure:86~106kPa

Notes:

1. The EMI measurements had been made in the operating mode produced the largest emission in the frequency band being investigated consistent with normal applications. An attempt had been made to maximize the emission by varying the configuration of the EUT.
2. The EMS measurements had been made in the frequency bands being investigated, with the EUT in the most susceptible operating mode consistent with normal applications. The configuration of the test sample had been varied to achieve maximum susceptibility.
3. Test Location:
Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
All tests were performed at:
Room101/301/401/102/202/302/402/502/602/702/802, No. 7-2, Caipin Road, Huangpu District, Guangzhou, Guangdong, China
Except Radiated Disturbance and Radiated Susceptibility were performed at:
Room102/104, No 203, KeZhu Road, Science City, GETDD Guangzhou, China
4. Measurement Uncertainty

TEST REPORT

No.	Item	Measurement Uncertainty
1	Conducted Emission (9 kHz-150 kHz)	2.80 dB
2	Conducted Emission (150 kHz-30 MHz)	2.23 dB
3	Conducted Emission with VP	1.77 dB
4	Conducted Emission with AAN	4.18 dB
5	Conducted Emission with CVP and CP	3.77 dB
6	Conducted Emission with CP	2.36 dB
7	Disturbance Power (30 MHz-300 MHz)	3.17 dB
8	Radiated Emission with CDNE	1.86 dB
9	Radiated Emission (9 kHz-150 kHz) LLAS	3.48 dB
10	Radiated Emission (150 kHz -30 MHz) LLAS	3.09 dB
11	Radiated Emission (9 kHz-30 MHz) Loop	3.64 dB
12	Radiated Emission (30 MHz-1 GHz)	4.26 dB
13	Radiated Emission (1 GHz-6 GHz)	4.46 dB
14	Radiated Emission (6 GHz-18 GHz)	4.96 dB
15	Radiated Emission (18 GHz-26.5 GHz)	5.16 dB
16	Radiated Emission (26.5 GHz-40 GHz)	5.16 dB

The measurement uncertainty describes the overall uncertainty of the given measured value during the operation of the EUT.

Measurement uncertainty is calculated in accordance with CISPR16-4-2:2011+A1:2014 +A2:2018.

The measurement uncertainty is given with a confidence of 95%, k=2.

Determination of the test conclusion is based on IEC Guide 115 in consideration of measurement uncertainty.

TEST REPORT

4. EQUIPMENT USED DURING TEST

Radiated Disturbance (30 MHz-1 GHz)

Equipment No.	Equipment	Model	Manufacturer	Cal. Due date (DD-MM-YYYY)	Last calibration date (DD-MM-YYYY)
EM030-04	3m Semi-Anechoic Chamber	9×6×6 m3	ETS-LINDGREN	9/04/2025	10/04/2024
EM031-02	EMI Test Receiver (9 kHz~7 GHz)	R&S ESR7	R&S	10/11/2025	11/11/2024
EM033-01	TRILOG Super Broadband test Antenna (30MHz-3GHz)	VULB 9163	SCHWARZBECK	8/12/2025	9/12/2024
EM031-02-01	Coaxial cable	/	R&S	9/04/2025	10/04/2024
EM036-01	Common-mode absorbing clamp	CMAD 20B	TESEQ	15/07/2025	16/07/2024
SA047-118	Digital Temperature-Humidity Recorder	RS210	YIJIE	15/07/2025	16/07/2024
EM031-04-01	EMC32 software (RE/RS)	V10.01.00	R&S	N/A	N/A

Electrostatic Discharge

Equipment No.	Equipment	Model	Manufacturer	Cal. Due date (DD-MM-YYYY)	Last calibration date (DD-MM-YYYY)
EM077-04	ESD Simulator	NSG437	TESEQ	20/08/2025	21/08/2024
SA047-176	Digital Temperature-Humidity Recorder	RS210	YIJIE	04/01/2025	05/01/2024

TEST REPORT

Radiated Susceptibility

Equipment No.	Equipment	Model	Manufacturer	Cal. Due date (DD-MM-YYYY)	Last calibration date (DD-MM-YYYY)
EM030-04	3m Semi-Anechoic Chamber	9×6×6 m ³	ETS LINDGREN	09/04/2025	10/04/2024
EM031-01	Signal generator	SMB100A	R&S	28/10/2025	29/10/2024
EM086-11	Power meter	NRP2	R&S	10/11/2025	11/11/2024
EM086-11-01	Power sensor	NRP-Z91	R&S	10/11/2025	11/11/2024
EM046-01	Power Amplifier	80RF1000-300	MILMEGA	03/03/2025	04/03/2024
EM046-03	Power Amplifier	AS0860-75-45	MILMEGA	02/09/2025	03/09/2024
EM061-05	Log. - Per. Broadband Antenna	VULP 9118 E	SCHWARZBECK	09/10/2025	10/10/2023
EM061-07	Stacked Log.-Per. Broadband Antenna	STLP 9149	SCHWARZBECK	09/10/2025	10/10/2023
EM034-01	Open Switch and Control Platform	OSP120/1505.3009K12	R&S	/	/
EM031-04-01	EMC32 software (RE/RS)	V10.01.00	R&S	/	/
SA047-118	Digital Temperature-Humidity Recorder	RS210	YIJIE	15/07/2025	16/07/2024

TEST REPORT

5. EMI TEST


5.1 Continuous Conducted Disturbance Voltage Test

Test Result: N/A

5.2 Radiated Emission below 1 GHz

Test Result: Pass

5.2.1 Block Diagram of Test Setup



5.2.2 Test Setup and Procedure

The measurement was applied in a semi-anechoic chamber. The EUT and simulators were placed on a 0.8m high foamed table above the horizontal metal ground plane. The turn table rotated 360 degrees to determine the position of the maximum emission level. The EUT was set 3 meters away from the receiving antenna which was mounted on an antenna mask. The antenna moved up and down between from 1meter to 4 meters to find out the maximum emission level.


Broadband antenna was used as receiving antenna. Both horizontal and vertical polarization of the antenna was set on measurement. In order to find the maximum emission, all of the interface cables were manipulated according to EN 55011 requirement during radiated test.

TEST REPORT

The bandwidth setting on Test Receiver was 120 kHz.
The frequency range from 30 MHz to 1000 MHz was checked

5.2.3 Test Data and Curve


Operation Mode: resistance measuring mode(worst)
Horizontal



All emission levels are more than 10 dB below the limit.

TEST REPORT

Vertical



All emission levels are more than 10 dB below the limit.

TEST REPORT

6. EMS TEST

Performance Criteria:

- Criterion A: The equipment shall continue to operate as intended during and after the test. No DEGRADATION OF PERFORMANCE or LOSS OF FUNCTION is allowed below a PERFORMANCE LEVEL specified in the user documentation, when the equipment is used as intended. In the case of applying immunity tests with continuous electromagnetic phenomena, the PERFORMANCE LEVEL may be replaced by a permissible LOSS OF PERFORMANCE which shall recover, without user intervention. A permissible LOSS OF PERFORMANCE is allowed within the PERFORMANCE LEVEL only when this information is clearly provided to the end user via documentation, such as the product user manual. No change in the operating state is allowed nor is loss of data.
- Criterion B: The equipment shall continue to operate as intended after the test. No DEGRADATION OF PERFORMANCE or LOSS OF FUNCTION is allowed below a PERFORMANCE LEVEL specified in the user documentation, when the equipment is used as intended. During the test, the equipment PERFORMANCE LEVEL may be replaced by a permissible LOSS OF PERFORMANCE if such LOSS OF PERFORMANCE is detailed in the EMC test plan. A permissible LOSS OF PERFORMANCE is allowed within the PERFORMANCE LEVEL only when this information is clearly provided to the end user via documentation, such as the product user manual. An unintended change of the operating state is allowed if self-recoverable. No loss of stored data is allowed.
- Criterion C: LOSS OF FUNCTION is allowed, provided the function is self-recoverable or can be restored by the operation of the controls. Recovery procedure shall be included in the user documentation. No permanent damage to the equipment is allowed.

Operation mode of EMS test:

Test Item	Operation mode
ESD immunity	Voltage /current/resistance measuring mode
Radiated EM field immunity	Voltage /current/resistance measuring mode
EFT immunity	N/A
Surge immunity	N/A
Inject current immunity	N/A
Power frequency magnetic field immunity	N/A
Voltage dips and interruption immunity	N/A

Note: "N/A" means Not Applicable in below text.


TEST REPORT

6.1 EN 61000-4-2(Pursuant to EN IEC 61326-1) Electrostatic Discharge Immunity

Performance criterion: B

Test Result: Pass

6.1.1 Block Diagram of Test Setup



Note: HCP means Horizontal Coupling Plane,

VCP means Vertical Coupling Plane

GRP means Ground Reference Plane

6.1.2 Test Setup and Procedure

The EUT was put on a 0.8m high wooden table 0.1m high for floor standing equipment standing on the ground reference plane (GRP) 3m by 2m in size, made by iron 1.0 mm thick.

A horizontal coupling plane (HCP) 1.6m by 0.8m in size was placed on the table, and the EUT with its cables were isolated from the HCP by an insulating support thick than 0.5mm. The VCP 0.5m by 0.5m in size & HCP were constructed from the same material type & thickness as that of the GRP, and connected to the GRP via a 470kΩ resistor at each end.

The distance between EUT and any of the other metallic surface excepted the GRP, HCP & VCP was greater than 1m.

The EUT was arranged and connected according to its functional requirements.

Direct static electricity discharges were applied only to those points and surface which were accessible to personnel during normal usage.

TEST REPORT

On each preselected points 10 times of each polarity single discharge were applied. The time interval between successive single discharges was at least 1s.

The ESD generator was held perpendicular to the surface to which the discharge was applied. The discharge return cable of the generator was kept at a distance of 0.2m whilst the discharge was being applied. During the contact discharges, the tip of the discharge electrode was touched the EUT before the discharge switch was operated. During the air discharges, the round discharge tip of the discharge electrode was approached as fast as possible to touch the EUT.

Indirect discharge was conducted to objects placed near the EUT, simulated by applying the discharges of the ESD generator to a coupling plane, in the contact discharge mode.

After each discharge, the ESD generator was removed from the EUT, the generator was then retriggered for a new single discharge. For ungrounded product, a grounded carbon fibre brush with bleeder resistors ($2 \times 470 \text{ k}\Omega$) in the grounding cable was used after each discharge to remove remnant electrostatic voltage.

For air discharge, a minimum of 10 single air discharges were applied to the selected test point for each such area.

TEST REPORT

6.1.3 Test Result

Direct Application of ESD

Direct Contact Discharge

Applied Voltage (kV)	No. of Discharge for each point per polarity	Result	Discharged Points
±4	10	N/A	Accessible metal parts of the EUT Conductive substrate with coating which is not declared to be insulating

Direct Air Discharge

Applied Voltage (kV)	No. of Discharge for each point per polarity	Result	Discharged Points
±2,±4,±8	10	Pass	All accessible points where contact discharge cannot be applied such as Displays, Indicators light, Keyboard, Button, Switch, Knob, Air gap, Slots, Hole and so on

Indirect Application of ESD

Horizontal Coupling Plane under the EUT

Applied Voltage (kV)	No. of Discharge for each point per polarity	Result	Discharged Point
±4	10	Pass	At the front edge of each HCP opposite the centre point of each unit of the EUT

Vertical Coupling Plane beside the EUT

Applied Voltage (kV)	No. of Discharge for each point per polarity	Result	Discharged Point
±4	10	Pass	The centre of the vertical edge of the coupling plane


TEST REPORT

6.2 EN 61000-4-3(Pursuant to EN IEC 61326-1) Radiated Electromagnetic Field Immunity

Performance criterion: A

Test Result: Pass

6.2.1 Block Diagram of Test Setup



TEST REPORT

6.2.2 Test Setup and Procedure

The test was conducted in a fully anechoic chamber to maintain a uniform field of sufficient dimensions with respect to the EUT, and also in order to comply with various national and international laws prohibiting interference to radio communications.

The equipment was placed in the test facility on a non-conducting table 0.8m high (for floor standing EUT, is placed on a non-conducting support 0.1m height).

For all ports connected to EUT, manufacturer specified cable type and length was used, for those cables no specification, unshielded cable applied. Wire was left exposed to the electromagnetic field for a distance of 1m from the EUT. The EUT was arranged and connected according to its functional requirements

Before testing, the intensity of the established field strength had been checked by placing the field sensor at a calibration grid point, and with the field generating antenna and cables in the same positions as used for the calibration, the forward power needed to give the calibrated field strength was measured. Spot checks was made at a number of calibration grid points over the frequency range 80MHz to 1000MHz, both polarizations was checked.

After calibration, the EUT was initially placed with one face coincident with the calibration plane.

The frequency range was swept from 80 MHz to 1000 MHz at 3V/m EM field, 1.4 GHz to 2.0 GHz at 3V/m EM field, 2.0 GHz to 6.0 GHz at 1V/m EM field with the signal 80% amplitude modulated with a 1 kHz sine-wave, pausing to adjust the r.f. signal level.

The dwell time at each frequency was 3s so as that the EUT to be exercised and be able to respond.

The step size was 1% of the fundamental with linear interpolation between calibrated points. Test was performed with the generating antenna facing each of the four sides of the EUT.

TEST REPORT

6.2.3 Test Result

Frequency (MHz)	Exposed Side	Field Strength (V/m)	Result
80 to 1000, 1400-2000	Front	3V/m (r.m.s.)	Pass
80 to 1000, 1400-2000	Left	3V/m (r.m.s.)	Pass
80 to 1000, 1400-2000	Rear	3V/m (r.m.s.)	Pass
80 to 1000, 1400-2000	Right	3V/m (r.m.s.)	Pass

Frequency (GHz)	Exposed Side	Field Strength (V/m)	Result
2.0 to 6.0	Front	1V/m (r.m.s.)	Pass
2.0 to 6.0	Left	1V/m (r.m.s.)	Pass
2.0 to 6.0	Rear	1V/m (r.m.s.)	Pass
2.0 to 6.0	Right	1V/m (r.m.s.)	Pass

TEST REPORT

6.3 EN 61000-4-4(Pursuant to EN IEC 61326-1) Electrical Fast Transient/Burst

Tested Port: ☐ AC power ☐ DC power ☐ Signal/Control

Performance criterion: B

Test Result: N/A

6.4 EN 61000-4-5(Pursuant to EN IEC 61326-1) Surge Immunity

Tested Port: ☐ AC power ☐ DC power ☐ Signal/ Control

Performance criterion: B

Test Result: N/A

6.5 EN 61000-4-6(Pursuant to EN IEC 61326-1) Injected Current (0.15 MHz to 80 MHz)

Tested Port: ☐ AC power ☐ DC power ☐ Signal/Control

Performance criterion: A

Test Result: N/A

6.6 EN IEC 61000-4-11(Pursuant to EN IEC 61326-1) Voltage Dips and Interruptions

Tested Port: AC power

Performance criterion: B (only for test level of 0%Ut with 0.5 cycle and 1 cycle), C

Test Result: N/A

TEST REPORT

6.7 EN 61000-4-8(Pursuant to EN IEC 61326-1) Power Frequency Magnetic Field Immunity

Tested Port: Enclosure

Performance criterion: A


Test Result: Not Applicable

Remark: Equipment containing no Hall elements or magnetic field sensors is not susceptible to magnetic field. Hence, this equipment is deemed to fulfil the magnetic field test.

TEST REPORT

7. APPENDIX I - PHOTOS OF TEST SETUP

Radiated emission (30 MHz–1000 MHz)




Radiated EM field immunity



TEST REPORT

ESD Immunity



TEST REPORT

8. APPENDIX II – PHOTOS OF EUT



Photo 1 - Front view



Photo 2 – Rear view

TEST REPORT



Photo 3 – Rear enclosure



Photo 4 - Internal view 1

TEST REPORT



Photo 5 – Internal view 2



Photo 6 – Internal view 3

TEST REPORT




Photo 7 – PCB view

*****End of Report*****